

# Accessible Parking Spaces

If parking spaces are provided for self-parking by employees or visitors, or both, then accessible spaces complying with the Americans with Disabilities Act Standards for Accessible Design (ADASAD) 502 shall be provided in each such parking area. Spaces need not be provided in the particular lot. They may be provided in a different location if equivalent or greater accessibility, in terms of distance from an accessible entrance and convenience is ensured.

Questions	Requirements
-----------	--------------

**Space requirements  
(accessible and van accessible)**

Are accessible spaces at least 96" wide with 60" wide access aisles? Yes  No

Are van accessible spaces at least 132" wide with 60" wide access aisles? Yes  No

Is there at least 98" of vertical clearance along the route to and from the van space as well as over the van space and access aisle? \_\_\_\_\_ "   
 Indicate Vertical Clearance

Is the surface of the space and access route firm and stable? Yes  No

Are parking spaces and access aisles level with each other and have a surface slope not exceeding 1:48 (2.08%) in all directions? Yes  No

Are the access aisles part of the accessible route to the accessible entrance? Yes  No

Are the accessible spaces on the shortest accessible route of travel to the accessible entrance? Yes  No

Are spaces and aisles designated with blue lines? Yes  No

**Number requirements**

Are an appropriate number of accessible parking spaces available? (See table at right.) Yes  No

Note: At least 1 of every 6 accessible spaces are to be van accessible. \_\_\_\_\_ / \_\_\_\_\_

**Sign requirements**


Are the vertical signs marked with the International Symbol of Accessibility? No. of Spaces  No. of Accessible Spaces

Are there signs reading "Van Accessible" at van accessible spaces? Yes  No


Are the signs located vertically, at least 60 inches from the bottom edge of the sign to the pavement? \_\_\_\_\_ "   
 Indicate Height

**Parking and Drop off Areas** – for the complete rule, see ADASAD 502, 3 and Indiana Code 5-16-9

**Features of Accessible Parking Spaces:**



**Access aisle for Parking Spaces:**



**Number of Spaces and Signage:**

Total Spaces	Accessible
1- 25	1 space
26-50	2 spaces
51-75	3 spaces
76-100	4 spaces
101-150	5 spaces
151-200	6 spaces
201-300	7 spaces
301-400	8 spaces
401-500	9 spaces
501-1000	2% of total
1001+	20+1 for ea. 100 over 1000

